

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		<b>PAGE 1 OF 55 PAGES</b>	
2. AMENDMENT/MODIFICATION NO. 05		3. EFFECTIVE DATE 03/24/2008		4. REQUISITION/PURCHASE REQ. NO. CB 080065		5A. TITLE: 2009 Presidential Inaugural Stands	
5B. PROJECT NO.		6. ISSUED BY  AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515		7. ADMINISTERED BY (If other than Item 6)  AOC - Procurement Division 2nd & D Streets, SW ATTN: Matt Hazlinsky Room H2-263 WASHINGTON, DC 20515		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code)				(X)		9A. AMENDMENT OF SOLICITATION NO. RFP080015	
				X		9B. DATED (SEE ITEM 11) 02/21/2008	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE				FACILITY CODE			

## 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 7 and 14, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)  
SEE LINE ITEMS

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  
See page 2 of this amendment.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Matt Hazlinsky Contracting Officer	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

NSN 7540-01-152-8070  
Previous edition unusable

STANDARD FORM 30 (REV. 10-83)  
Prescribed by GSA FAR (48 CFR) 53.243

RFP080015

Amendment No. 005  
RFP No. 080015

This Amendment No. 005 is issued to the above referenced RFP Number in order to:

1. Answer any questions asked as of March 24, 2008,
2. Close the period for accepting questions. As of this amendment, no additional questions will accepted in response to the RFP.

Attachments:

Question (1 page)

**CONSTRUCTION OF 2009 PRESIDENTIAL INAUGURAL STANDS  
WASHINGTON, D.C.  
RFP No. 080015**

**CLARIFICATION QUESTIONS AND ANSWERS**

1. Question: Sheet S102. On the plan copy, the two marked "Dwarf walls" that adjoin the stairs leading to the Safe Rooms are partially load bearing but do not have any footings indicated. Please advise of design intent especially that the outer wall is partially set in the planter.

Answer: SHEET S102 INDICATES THE FRAMING IN PLAN VIEW. IT DIFFERS FROM THE LEFT SIDE OF THE PAGE TO THE RIGHT. TO THE LEFT OF THE CENTERLINE (NORTH), THE FRAMING MEMBERS THAT'S SHOWN ARE THE FLOOR JOISTS FOR THE LARGE SEMICIRCULAR MAIN STAGE AREA. TO THE RIGHT (SOUTH), THE JOISTS THAT SHOW THERE SUPPORT THE DECK OF THE SAFE ROOM AREA. THE DWARF WALLS INDICATED ARE MERELY TO HOLD UP THE END OF THE SAFE ROOM DECK. DETAIL 2/S103 SHOWS THE MANNER IN WHICH SUPPORTING WALLS ARE PLACED WITHIN THE FOUNTAIN, ATOP THE EXISTING CONCRETE WALKWAY THAT SURROUNDS THE FOUNTAIN, AND ALSO IN THE AREAS OF THE PLANTERS. NOTE THAT NO LOAD BEARING IS TO BE BORNE BY THE WALLS OF THE FOUNTAIN OR THE WALLS OF THE PLANTER. THE LOADS ARE TO BE TAKEN UP BY THE FILL IN THE FOUNTAIN AND BY BLOCKS THAT ARE PLACED ON THE CONCRETE WALK OR IN THE DIRT OF THE PLANTER.